



Australian Government

National Measurement Institute

Pattern Approval Number: 14/2/154

Manufacturer/Make: IME

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
CONTO D4 PT	Electronic	Transformer-operated	1	3	4	50 Hz	230(400) V AC to 240(415) V AC	- [1]	1 A, 5 A	Adjustable
CONTO D1	Electronic	Direct connected	1	1	2	50 Hz	184-276 V AC	32 A	32 A	1 imp/Wh
NEMO96HD	Electronic	Transformer-operated	0.5	3	3 or 4	50 Hz	50(80) V AC to 290(500) V AC	- [1]	1 A, 5 A	Adjustable
NEMO3DSHPN2	Electronic	Transformer-operated	2	3	4	50 Hz	57(100) V AC to 260(450) V AC	- [1]	5 A	Adjustable
NEMOD4L (N2 Open)	Electronic	Transformer-operated	1	3	4	50 Hz	30(60) V AC to 260(450) V AC	- [1]	5 A	Adjustable
NEMOD4L+ (BACnet)	Electronic	Transformer-operated	1	3	4	50 Hz	45(80) V AC to 278(480) V AC	- [1]	1 A, 5 A	Adjustable

Note [1]: Values are not specified. Various values may be applicable.