

## APPENDIX 1

NMI 14/2/167

Rev 0

8/03/13



**Australian Government**  
**National Measurement Institute**

**Pattern Approval Number:** NMI 14/2/167  
**Manufacturer/Make:** ABB

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
A44 452-100	Electronic	Transformer-operated	0.5	3	4	50 Hz	3x57.7/100 V AC to 3x288/500 V AC	1 A	32 A	5000 imp/kWh
EE22	Electronic	Direct-connected	2	1	2	50 Hz	230 V AC	5 A	32 A	1, 10, 100, 1000 imp/kWh
OD1365	Electronic	Direct-connected	1	1	2	50 Hz	230 V AC	5 A	65 A	1000 imp/kWh
OD4165	Electronic	Direct-connected	2	3	4	50 Hz	3x230/400 V AC	5 A	65 A	100 imp/kWh
OD4110	Electronic	Transformer-operated	2	3	4	50 Hz	3x230/400 V AC	5 A	10 A	1000 imp/kWh