



Australian Government

National Measurement  
Institute

Bradfield Road, West Lindfield NSW 2070

## Certificate of Approval

### No 14/2/172

Issued by the Chief Metrologist under Regulation 60  
of the  
National Measurement Regulations 1999

This is to certify that an approval for use for trade has been granted in respect of the instruments herein described.

Hagemeyer Model HAGEC150 Class 1 Electricity Meter

**NOTE:** This Certificate relates to the suitability of the pattern of the instrument for use for trade only in respect of its metrological characteristics. This Certificate does not constitute or imply any guarantee of compliance by the manufacturer or any other person with any requirements regarding safety.

This approval does NOT permit the verification of new instruments. It does not become subject to review.

#### DOCUMENT HISTORY

Rev	Reason/Details	Date
0	Pattern approved – certificate issued	18/06/13
1	Pattern amended (model number) – certificate issued	6/07/13

#### CONDITIONS OF APPROVAL

##### General

This approval applies only to existing instruments in the field or held in stock.

Instruments may be relocated and reinstalled but shall not be altered in any way other than to replace damaged components with equivalent components.

Signed by a person authorised by the Chief Metrologist to exercise their powers under Regulation 60 of the *National Measurement Regulations 1999*.

A handwritten signature in black ink, appearing to read 'Dr A Rawlinson', with a horizontal line underneath.

Dr A Rawlinson

## TECHNICAL SCHEDULE No 14/2/172

### 1. Description of Pattern

approved on 18/06/13

A Hagemeyer model HAGEC150 polyphase class 1 direct connect static watt hour meter used to measure electrical energy.

#### 1.1 Field of Operation

The field of operation of the measuring system is determined by the following characteristics:

- Number of phases 3
- Number of wires 3
- Reference frequency 50 Hz
- Reference voltage 3x240 V AC
- Reference currents:      Basic current,  $I_b$       32 A  
                                  Maximum current,  $I_{max}$     100 A
- Accuracy Class 1

#### 1.2 Markings

- Meter constant 1000 imp/kWh

#### 1.3 Verification Provision

Provision is made for the application of a verification mark.

~ End of Document ~