



Australian Government
Department of Industry,
Science and Resources

**National
Measurement
Institute**

36 Bradfield Road, West Lindfield NSW 2070

Certificate of Approval
NMI 14/3/63

Issued by the Chief Metrologist under Regulation 60
of the
National Measurement Regulations 1999

This is to certify that an approval for use for trade has been granted in respect of the instruments herein described.

Spire Metering Technology 280W-R Ultrasonic Model Water Meter

submitted by Access Petrotec Pty Ltd
Unit 1, 13-17 Sorbonne Crescent
Canning Vale WA 6155

NOTE: This Certificate relates to the suitability of the pattern of the instrument for use for trade only in respect of its metrological characteristics. This Certificate does not constitute or imply any guarantee of compliance by the manufacturer or any other person with any requirements regarding safety.

This approval has been granted with reference to document NMI R 49-1 Water Meters Intended for the Metering of Cold Potable Water and Hot Water, *Part 1 Metrological and Technical Requirements*, dated May 2022.

This approval is subject to review at the decision of the Chief Metrologist in accordance with the conditions specified in the document NMI P 106.

DOCUMENT HISTORY

Rev	Reason/Details	Date
0	Pattern & Variant 1 approved – certificate issued	09/05/23

CONDITIONS OF APPROVAL

General

Instruments purporting to comply with this approval shall be marked with pattern approval number 'NMI 14/3/63' and only by persons authorised by the submitter.

It is the submitter's responsibility to ensure that all instruments marked with this approval number are constructed as described in the documentation lodged with the National Measurement Institute (NMI) and with the relevant Certificate of Approval and Technical Schedule. Failure to comply with this Condition may attract penalties under Section 19B of the National Measurement Act and may result in cancellation or withdrawal of the approval, in accordance with document NMI P 106.

Signed by a person authorised by the Chief Metrologist to exercise their powers under Regulation 60 of the *National Measurement Regulations 1999*.



Darryl Hines
Manager
Policy and Regulatory Services

TECHNICAL SCHEDULE No 14/3/63

1. Description of Pattern **approved on 09/05/23**

A Spire Metering Technology 280W-R ultrasonic model water meter used to measure cold potable water supplies for trade.

1.1 Field of Operation

The field of operation of the measuring system using the Spire Metering Technology 280W-R ultrasonic DN15 size water meter is determined by the following characteristics:

Minimum flow rate, Q ₁ :	0.010 m ³ /h
Transition flow rate, Q ₂ :	0.016 m ³ /h
Maximum continuous flow rate, Q ₃ :	2.5 m ³ /h
Overload flow rate, Q ₄ :	3.13 m ³ /h
Flow rate ratio, Q ₃ /Q ₁ :	250
Temperature class:	T50
Maximum admissible temperature:	50 °C
Maximum admissible pressure:	1600 kPa
Pressure loss class:	Δp 63
Accuracy class:	2
Flow profile sensitivity class:	U5/D3
Electromagnetic class:	E2 (industrial)
Environmental class:	B (indoors)
Orientation:	All orientations with the indicating device positioned top or side
Flow Direction:	Forward only
Power supply:	Replaceable battery (Lithium, 3.6 V)

1.2 Features/Functions

The pattern (Figure 1) consists of an ultrasonic flow sensor and electronic indicating device (calculator/indicator) and has features/functions as listed below:

Connection type:	Threaded end connections
Display:	A digital, electronic, liquid crystal display (Figure 2) allowing for a maximum indication range of 9,999,999.99 m ³ in 0.01 m ³ increments
Materials:	Flow sensor: Brass Flow converter: Stainless steel/Plastic
Meter length:	165 mm
Non-return device(s):	None

1.3 Conditions

1.3.1 Installation Conditions:

No flow straightener or flow conditioner is required.

The flow profile sensitivity class is U5/D3.

1.3.3 Water Quality

The meter is approved for use in the metering of potable water supplies.

1.4 Software Version

The meter is approved for use with software version - Version 4913.

1.5 Verification Provision

Provision is made for the application of a verification mark.

1.6 Sealing Provision

The meter and its electronics are sealed via sealing caps that are permanently adhered to the 2 screws that are horizontally aligned with the display (Figure 3). The seals prevent access to the screws required to open the water meter top cover/face plate.

1.7 Descriptive Markings and Notices

Instruments are marked with the following data, either grouped or distributed on the casing, the indicating device dial or an identification plate (Figure 2):

Manufacturer's name or mark	...
Serial number	...
Pattern approval number	NMI 14/3/63
Numerical value of maximum continuous flow rate, Q_3	...
Flow rate ratio, Q_3/Q_1	...
Unit of measurement	m^3
Temperature class ⁽¹⁾	T50
Maximum admissible pressure ⁽²⁾	1600 kPa
Pressure loss class ⁽³⁾	Δp 63
Orientation ⁽⁴⁾	...
Flow profile sensitive class ⁽⁵⁾	U5/D3
Direction of flow	→ or similar
Accuracy class ⁽⁶⁾	2

⁽¹⁾ Optional for temperature class T30

⁽²⁾ Optional for meters with MAP of 1400 kPa or 600 kPa for $DN \geq 500$

⁽³⁾ Optional for pressure loss class Δp 63

⁽⁴⁾ Optional for meters approved for all orientations

⁽⁵⁾ Optional for U0/D0 meters and accuracy class 2.5 meters

⁽⁶⁾ Optional for accuracy class 2 meters

For instruments that incorporate electronic devices, the following information can either be physically marked on the instrument or provided electronically via the indicating device or similar means:

Electromagnetic class	E2
Environmental class	B
For meters with an external power supply	the voltage and frequency
For battery powered meters	a replacement date or similar indication of expected battery life

2. Description of Variant 1

approved on 09/05/23

The Pattern and Variants are approved with a range of different sizes, flowrates and associated characteristics as specified in Table 1 below. The Pattern is shown in **Bold** for completeness.

Table 1 – Meter sizes, flowrates and related information

Meter size	DN15	DN20	DN25
Minimum flowrate Q ¹ (m ³ /h)	0.010	0.016	0.025
Transitional flowrate Q ² (m ³ /h)	0.016	0.026	0.040
Maximum continuous flowrate Q ³ (m ³ /h)	2.5	4	6.3
Overload flowrate Q ⁴ (m ³ /h)	3.125	5	7.875
Ratio Q ³ /Q ¹	250		
Meter length (meter only) mm	165	154 or 190	260
Verification scale interval (m ³)	0.01		

TEST PROCEDURE No 14/3/63

Water meters tested for verification shall comply with the Certificate of Approval, Technical Schedule, and the maximum permissible errors for initial and subsequent verifications at the operating conditions in effect at the time of verification. Maximum permissible errors for the initial and subsequent verification of water meters are given in the *National Trade Measurement Regulations 2009* (Cth).


Water meters shall be verified in accordance with NITP 14 *National Instrument Test Procedures for Utility Meters*.

The following exceptions apply for accuracy class 2 meters:

- The working water temperature range for verification is dependent on the temperature class of the meter as follows:
 - T30, T50: $20\text{ °C} \pm 10\text{ °C}$;
 - T70 to T180: $20\text{ °C} \pm 10\text{ °C}$ and $50\text{ °C} \pm 10\text{ °C}$;
 - T30/70 to T30/180: $50\text{ °C} \pm 10\text{ °C}$.
- Where a meter is tested with a working water temperature greater than 30 °C , the maximum permissible errors shall be:
 - $\pm 5\%$ within the flowrate range $Q_1 \leq Q < Q_2$; and
 - $\pm 3\%$ within the flowrate range $Q_2 \leq Q \leq Q_4$.

NOTE: NMI reserves the right to vary this procedure. Any such variation shall be notified in writing by NMI.

FIGURE 14/3/63 – 1



SpireMT 280W-R DN15 Water Meter (the pattern)

FIGURE 14/3/63 – 2



Example of the display/indicating device and required markings

FIGURE 14/3/63 – 3



Sealing caps preventing access to mounting screws

~ End of Document ~