

Australian Government

Department of Industry, Science and Resources

National Measurement Institute

36 Bradfield Road, West Lindfield NSW 2070

# Certificate of Approval NMI 14/2/86

Issued by the Chief Metrologist under Regulation 60 of the National Measurement Regulations 1999

This is to certify that an approval for use for trade has been granted in respect of the instruments herein described.

Secure Model i-Credit 510 Class 1 Electricity Meter

submitted by Secure Meters (Australia) Pty Ltd 39-41 Fennell Street Port Melbourne VIC 3207

**NOTE:** This Certificate relates to the suitability of the pattern of the instrument for use for trade only in respect of its metrological characteristics. This Certificate does not constitute or imply any guarantee of compliance by the manufacturer or any other person with any requirements regarding safety.

This approval has been granted with reference to Pathway 1 in the document NMI M 6-1 *Electricity Meters. Part 1: Metrological and Technical Requirements*, July 2020.

This approval is subject to review at the decision of the Chief Metrologist in accordance with the conditions specified in the document NMI P 106.

Rev	Reason/Details	Date
0	Pattern approved – interim certificate issued	3/06/15
1	Pattern amended (validity) – interim certificate issued	3/12/15
2	Pattern approved – certificate issued	11/04/16
3	Variant 2 approved – certificate issued	9/01/17
4	Variant 3 approved – certificate issued	24/06/22
5	Address updated – certificate issued	07/01/25

## DOCUMENT HISTORY

## CONDITIONS OF APPROVAL

## General

Instruments purporting to comply with this approval shall be marked with pattern approval number 'NMI 14/2/86' and only by persons authorised by the submittor.

It is the submittor's responsibility to ensure that all instruments marked with this approval number are constructed as described in the documentation lodged with the National Measurement Institute (NMI) and with the relevant Certificate of Approval and Technical Schedule. Failure to comply with this Condition may attract penalties under Section 19B of the National Measurement Act and may result in cancellation or withdrawal of the approval, in accordance with document NMI P 106.

Signed by a person authorised by the Chief Metrologist to exercise their powers under Regulation 60 of the *National Measurement Regulations 1999*.

**Darryl Hines** Manager Policy and Regulatory Services

## TECHNICAL SCHEDULE No 14/2/86

## 1. Description of Pattern

### approved on 3/06/15

A Secure model i-Credit 510 single phase class 1 direct connect static watt hour meter (Figures 1 and 2) used to measure electrical energy.

## 1.1 Field of Operation

The field of operation of the measuring system is determined by the following characteristics:

•	Number of phases	1			
•	Number of wires	2			
•	Reference frequer	50 Hz			
٠	Reference ambient temperature ranges:				
	specified ra	−10 to 60 °C			
	limit range o	−20 to 70 °C			
•	Rated voltage		230 V AC		
٠	Rated currents:	Basic current, $I_{_{ m b}}$	10 A		
		Maximum current, I <sub>max</sub>	100 A		
٠	Meter constant		1 Wh/imp		
•	Accuracy class		1		

## 1.2 Features/Functions

- Two (2) elements
- Electronic (LCD) digital indicator
- ANSI optical port
- Two pulse output LEDs for Wh and Varh
- Bottom connect rectangular base
- Internal synchronous and crystal clock
- Measurement in both positive and negative directions (export and import)

## 1.3 Descriptive Markings

Instruments are marked with the following data, together in one location, in the form shown at right:

Manufacturer's name or mark	
Model designation	
Serial number	
Pattern approval mark	NMI 14/2/86
Number of phases	
Number or wires	
Reference frequency	Hz
Meter constant	
Rated voltage	AC
Rated currents:	I <sub>ь</sub> А
	$I_{max} \dots A$
Accuracy class	Class 1

#### 1.4 Verification Provision

Provision is made for the application of a verification mark.

#### 1.5 Sealing Provision

The meter is sealed during manufacture. Provision is made for the terminal cover to be sealed by the application of one or more mechanical seals (Figure 2).

#### 1.6 Harmonics

Instruments purporting to comply with this approval are suitable for use where the harmonics do not exceed those specified in Pathway 1 of the document NMI M 6-1 Electricity Meters. Part 1: Metrological and Technical Requirements, July 2020.

#### 2. **Description of Variant 1**

Similar to the pattern but having some, or all, of the following features/functions.

- One (1) element
- Optional integrated 100 A mains supply contactor
- Optional integrated load control relays (2 A, 31.5 A or 60 A)
- Optional integrated ripple control receiver
- Field replaceable AMI communication module

#### 3. **Description of Variant 2**

A Secure model i-Credit 511 electronic single phase class 1 direct connect static watt hour meter used to measure electrical energy. This variant has the same Field of Operation and Features as the pattern except:

- 1 or 2 elements
- Optional fitted cellular communication module

#### 4. **Description of Variant 3**

This variant has the same Field of Operations and Features/Functions as the pattern, or variant 1, except for the following:

Rated voltage

## **TEST PROCEDURE No 14/2/86**

Instruments tested for initial verification shall comply with the certificate of approval and technical schedule, and the maximum permissible errors for verifications at the operating conditions in effect at the time of verification.

The maximum permissible errors are specified in the National Trade Measurement Regulations 2009 (Cth).

Electricity meters shall be verified in accordance with the following National Instrument Test Procedures:

- NITP 14.0 Utility Meters general requirements
- NITP 14.2 Utility Meters electricity meters

## approved on 9/01/17

approved on 24/06/22

240 V AC


## approved on 11/04/16

FIGURE 14/2/86 - 1



## Secure Model i-Credit 510 Electricity Meter (The Pattern)

FIGURE 14/2/86 - 2



Model i-Credit 510 Showing Typical Mechanical Sealing (The Pattern)

## FIGURE 14/2/86 - 3



Secure Model i-Credit 511 Electricity Meter (Variant 2)

~ End of Document ~